

**RESPONSES TO QUERIES ON EXPRESSIONS OF INTEREST**  
**DOCUMENT**

**January 18, 2016**

1. What is the correct closing date? Document has two dates and times.

**Correct closing date is February 5, 2016 and closing time is 16:00 hours Eastern Standard Time.**

2. How many desalination plants are being considered?

**Two (2) are to be built of 30,000cubic meters/day capacity each..**

3. What water wells are to be dug?

**It is planned to use onshore groundwater wells to extract the feed water (seawater) rather than use a seawater intake offshore. The Brine is also expected to be disposed of through deep well injection on land.**

4. Where are the hydro-geological studies to be conducted to determine the best location of feed water wells?

**This will be done on defined sites chosen for locating the plants.**

5. Planned timeframe indicates an award in first quarter of 2016. Is this after the selection of RFP?

**Yes this is expected to be after review of RFP submissions from the shortlisted firms.**